





Chaussée de Vilvorde, 156 Vilvoordsesteenweg 156 B-1120 Bruxelles/Brussel Tel.: 32 (0)2 264 03 60 Fax: 32 (0)2 268 89 58 http://www.apragaz.com info@apragaz.com



## **EC TYPE EXAMINATION**

## In accordance with module B of Directive 2014/90/EU on **Marine Equipment**

Certificate N° 15/SP/3573-1-REV 0

Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN

Concerned Equipment: Item n° MED/3.2: Portable Stored Pressure Fire Extinguisher

Type: PP 6 PS / PP 6 HDI

Nominal charge: 6 kg. Powder ABC 30 (effective 30): PP6PS / 6 kg Powder ABC 40 (radikal 40): PP6HDI

Fire ratings: PP6PS: 27A - 144B - C / PP6HDI: 34A - 233B - C

Temperature range: min.-20°C / max. +60°C

EN3-7 Test certificate: AFNOR PP6PS: EP6 152 561 A0 / PP6HDI: EP6 152 501 A0

The manufacturer is allowed to affix the marine CE mark followed by the notified body n° and the year of manufacturing (four digits) to approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with.

## The approval is valid until 01/03/2025

APRAGAZ, acting within the scope of its notification for the Directive 2014/90/EU, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU as amended, on base of the documentation and samples supplied for review and approbation.

Date: 18/03/2020 Name: B.Neve Position **General Manager** 

Notified body identification

number:

0029

Signature

APRAGAZ

Belgium

Notified body stamp:

Inspecting **Authority** 

Notified body reference:

P4567/000